

QUALITY REPORT

Report number: 14001/00015826/26
Place of sampling: Gdański Terminal Gazowy
Sample object: shore tank no 12
Product: propane
Sample type: general
Date of sampling: 09.02.2026; 09:05 hrs
Sample number: 19060922
Customer reference number: WGT No: 08/02/2026
Testing completed: 09.02.2026
Date of issue: 09.02.2026

NAME	METHOD	UNIT	RESULT
C1	PN-EN 27941:2015-12 ¹	% m/m	<0,1
C2	PN-EN 27941:2015-12 ¹	% m/m	1,0
C3	PN-EN 27941:2015-12 ¹	% m/m	96,4
C4	PN-EN 27941:2015-12 ¹	% m/m	2,6
C5	PN-EN 27941:2015-12 ¹	% m/m	<0,1
Total olefines content	PN-EN 27941:2015-12	mg/kg	<10
1,3-butadiene content	PN-EN 27941:2015-12	mg/kg	<10
Methane	PN-EN 27941:2015-12 ¹	% m/m	<0,1
Ethane	PN-EN 27941:2015-12 ¹	% m/m	1,0
Ethene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
Propane	PN-EN 27941:2015-12 ¹	% m/m	96,4
Propadiene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
Propene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
i-Butane	PN-EN 27941:2015-12 ¹	% m/m	1,9
n-Butane	PN-EN 27941:2015-12 ¹	% m/m	0,7
Trans-2-butene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
1-Butene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
i-Butene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
Cis-2-Butene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
2,2-Dimethylpropane	PN-EN 27941:2015-12 ¹	% m/m	<0,1
i-Pentane	PN-EN 27941:2015-12 ¹	% m/m	<0,1
1,2-butadiene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
n-Pentane	PN-EN 27941:2015-12 ¹	% m/m	<0,1
1,3-butadiene	PN-EN 27941:2015-12 ¹	% m/m	<0,1
Total sulphur content	PN-EN 17178:2020-01 ¹	mg/kg	1,3
Residue of mineral oil	PN-EN 15471:2017-08	mg/kg	<20
Density at 15,6 °C	PN-C-96008:1998	t/m ³	0,507
Absolute vapour pressure at -15 °C	PN-C-96008:1998	MPa	0,306
Absolute vapour pressure at 40 °C	PN-C-96008:1998	MPa	1,416
Absolute vapour pressure at 70 °C	PN-C-96008:1998	MPa	2,602
Calorific value	PN-C-96008:1998	kJ/kg	46350
Hydrogen sulfide content	PN-EN ISO 8819:2000 ¹	-	not detected
Water content	PN-C-96008:1998	-	not detected
Odour	PN-EN 589:2024-08 Annex A ¹	-	distinctive and unpleasant
Copper strip corrosion (1 h at 40 °C)	PN EN ISO 6251:2001 ¹	-	class 1

Remarks:

Sample was taken from the tank as above in accordance with EN ISO 4257:2001¹.

¹ Accredited method, PCA Accreditation no AB 1278.

This report reflects only the findings at the time and place of the inspection and testing.

This report shall not be partially copied and reproduced without the written permission of the laboratory.

Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

Results approved by: Kamil Borsuk

Signed by: Joanna Daraszkiwicz

Issued by: Saybolt Poland sp. z o.o.